



Product Service

Attestation of Conformity

No. D6 12 11 81493 003

Holder of Attestation: **SHIMGE PUMP INDUSTRY GROUP CO.,LTD.**

Dayangcheng Industrial
317525 Wenling, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Circular Pumps
Circulation pump**

Model(s): **APS32-6-180**

Parameters:

Rated voltage:	230Vac
Rated frequency:	50/60Hz
Rated input power:	45W
Protection class:	I
Degree of protection:	IP 42
Rated Head:	2.5 m
Rated Flow:	2.0 m ³ /h
Declared EEI:	Less than 0.20

Implementation Measure EC Regulation
No 641/2009: 22.07.2009
Amended By EC Regulation
622/2012: 11.07.2012
Stage 2 (01 Aug. 2015)

Tested according to: PPP 11093B:2012
EN 1151-1:2006

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the sample submitted to TÜV SÜD PRODUCT SERVICE GMBH for testing and evaluation and to its technical documentation. See also notes overleaf.

Test report no.: 704011285802-02

Date, 2012-11-20

(Jianying Lu)



Page 1 of 1