



Strojirenský zkušební ústav, s.p. (Engineering Test Institute, Public Enterprise),
Hudcova 424/56b, 621 00 Brno, Czech Republic

CERTIFICATE

B-30-00292-13

Manufacturer: Kiturami Boiler Co., Ltd.
#300 Wolgok-Ri, Cheongdo-Eup,
Cheongdo-Gun, Gyeongsangbuk-Do
The Republic of Korea

Products: Heating boilers burning wood with manual fuel supply

Type designation: KF-35, KF-60

The Engineering Test Institute, Public Enterprise, hereby certifies that the characteristics of the product samples concerned have been found conforming to the requirements of


EN 303-5:2012 (with the exception of Deviations C.2.2, C.2.3, C.5.1, C.5.2, and C.6, Annex 6).

The present Certificate has been issued based on Test Report 30-11981/T of 2013-05-21, issued by the Engineering Test Institute, Public Enterprise.

The rules for using the Certificate are specified on Page 2.

Brno, 2013-05-31




Ing. Tomáš Hruška
Director

Specification of products:

Size	Heat output Wood [kW]	Water volume [l]	Max. operating temperature [°C]	Max. operating pressure [bar]	Weight [kg]
KF-35	30	90	80	3	410
KF-60	38	130			550

RULES FOR USING THE CERTIFICATE:

For purpose of placing the products on the market, the Certificate may only be used provided the normative document specified on Page 1 remains valid.

The Certificate may only be used as a certificate for the products specified on Pages 1 and 2. This also applies to its use in advertising, promotional and commercial materials. Unauthorised or deceitful use of the Certificate may result in its withdrawal.

It is prohibited to change, amend or overwrite the data contained in the Certificate.

The Certificate may not be used to substantiate the characteristics of the products changed without the consent of the Engineering Test Institute in such a way that conformity with the technical requirements specified on Page 1 has been affected.

